

**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**DISTRICT WATER TESTING LABORATORY, HISAR**

Website :- <https://phedharyana.gov.in/>

Memo No:- 1118

Date:- 13/06/2023

**Subject : Physical / Chemical Examination Report of Water Sample**

HC-28

Sample ID/Classification : HSR/01035/6/2023 / Private	<b>Sample Details</b>	<b>Date &amp; Time</b>
Sender : SUKH RAM MEMORIAL PUBLIC SCHOOL22039	Collected By	
Location : , 8KM STONE AGROHA ADAMPUR ROAD, VILLAGE KALIRAWAN	Collection Date	08/06/2023 at 12:06
Sample Description : Drinking Water	Received at lab	09/06/2023 at 13:59
Latitude / Longitude : 75.562238 / 29.298119	Analysis Start Date	08/06/2023
	Analysis End Date	13/06/2023
	Sample Quantity	2 Ltr.

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	175	500 mg/ltr.	2000 mg/ltr.	APHA2540 C; 2017
2	Total Hardness as CaCO <sub>3</sub>	79.6	200 mg/ltr.	600 mg/ltr.	APHA2340 C; 2017
3	Calcium as Ca	23.08	75 mg/ltr.	200 mg/ltr.	APHA3500-Ca B; 2017
4	Magnesium as Mg	5.34	30 mg/ltr.	100 mg/ltr.	APHA3500 Mg B; 2017
5	Iron as Fe	0.01	1.0 mg/ltr.	1.0 mg/ltr.	APHA3500-Fe B; 2017
6	Chloride as Cl	22.68	250 mg/ltr.	1000 mg/ltr.	APHA4500 Cl-B; 2017
7	Sulphate as So <sub>4</sub>	34	200 mg/ltr.	400 mg/ltr.	APHA4500-So <sub>4</sub> -E
8	Fluoride as F	0.139	1.0 mg/ltr.	1.5 mg/ltr.	APHA 4500-F--C
9	Nitrate as No <sub>3</sub>	0.42	45 mg/ltr.	45 mg/ltr.	APHA 4500-NO <sub>3</sub> - D
10	pH @ 25°C	7.24	6.5 - 8.5	6.5 - 8.5	APHA4500-H+ B; 2017
11	Total Alkalinity	72.8	200 mg/ltr.	600 mg/ltr.	APHA 2320 B; 2017

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.  
Based on the tested parameters, the water sample is found "**POTABLE**"



Sample analyzed by :

  
**RAJEEV KUMAR, CHEMIST**  
 DISTRICT WATER TESTING LABORATORY, HISAR  
 email:-chemist.hisar@phedharyana.gov.in

-----END OF TEST REPORT-----